



BUREAU OF FIRE PREVENTION WATER FLOW TESTS

The Water Department cycles the level of water storage tanks. Fire protection contractors have experienced difficulties while performing fire pump or dry pipe trip tests because the water level of the dominant water supply tank during the test was lower than at the time of the flow test.

WATER DEPARTMENT TEST FORMS

- Record water flow test data
- List the maximum and minimum operating levels of the dominant water supply tank for a given test and the level of the tank at the time of the test
- Shall be included with the fire sprinkler plan submittal to the Bureau of Fire Prevention

FIRE PROTECTION SYSTEM DESIGN

- Account for the worst case water supply condition

WATER FLOW TESTING CONTACT

Fort Worth Water Department – (817) 392-5898