

CITY OF FORT WORTH
WATER DEPARTMENT

**Water and Sanitary Sewer Rehabilitation Contract 101
City Project No. 02722**

ADDENDUM NO. 3

Unit 1 – Water

Unit 2 – Sanitary Sewer

Unit 3 - Paving

Addendum No 3 issued: November 10, 2020

Bid Receipt Date: November 19, 2020

This Addendum forms part of the Specifications and Contract Documents and modifies the original Specifications and Contract Documents. Bidders shall acknowledge receipt of this Addendum in the space provided below and acknowledge receipt on the outer envelope in your bid. Failure to acknowledge receipt of this addendum could subject the bidder to disqualification.

The Specifications and Contract Documents for City Project No. 02722 are hereby revised by this Addendum No. 3 as follows:

- 1. Specifications Section 00 00 00 – Table of Contents – attached herein and to be REPLACED in its entirety**
- 2. Specifications Section 00 21 13 - Instructions to Bidders – Page 6 of 10 attached herein and to be REPLACED to correct the Addenda Folder website.**
- 3. Section 00 41 00 – Bid Form – attached herein and to be REPLACED in its entirety.**
- 4. Specifications Section 01 35 13 – Special Project Procedures – attached herein and to be REPLACED in its entirety.**
- 5. Specifications Section 33 12 10 – Water Services 1-inch to 2-inch – attached herein and to be ADDED to the Specifications to include Deviations.**
- 6. Construction Plan Set sheets 4, 6, 9, 15, 16, 17, 18, 19, 20, 22, 24, 25, 26 and 27 attached herein and to be REPLACED in their entirety.**

Clarification:

- In locations that the property line conflicts with an existing structure, cleanout lids may be placed in the sidewalk WITH THE APPROVAL of the Project Manager. Cleanout lids in the sidewalk must be cast iron.
- Permanent asphalt repair shall have 2" Asphalt Pavement Type D (see revision sheet 27).

This Addendum No. 3 forms part of the Specifications and Contract Documents for the above referenced project and modifies the original Project Manual & Contract documents of same.

Acknowledge your receipt of Addendum No. 3 by completing the requested information at the following locations:

- (1) in the space provided in Section 00 41 00, Bid Form, Page 3 of 3, and
- (2) indicate in upper case letters on the outside of your sealed bid envelope

"RECEIVED AND ACKNOWLEDGED ADDENDUM NO. 3"

Include a signed copy of Addendum No. 3 in the sealed bid envelope at the time of bid submittal. Failure to acknowledge receipt of Addendum No.3 below could cause the subject bidder to be considered "NONRESPONSIVE", resulting in disqualification.

Addendum No. 3

RECEIPT ACKNOWLEDGED:

By: _____

Company: _____

Christopher Harder, P.E.
Director, Water Department

By: Tony Sholola
Tony Sholola, P.E.

Assistant Director, Water Department